Domestic Water Pumps: A Critical Review of Common Operational Problems, Energy Efficiency, and Maintenance Practices

Prof. Pravin A. Sapane[1], Prof. Nikhil Ekotkhane[2], Aryan U. Ingale[3], Miss Sapana S. Surjuse[4], Atanu Mallick[5], Akshay Shinde[6], Prajwal V. Badhiye[7], Miss Dipti Manohar[8]

[1] *HOD, Department of Mechanical Engineering, R V Parankar College of Engineering & Technology, Arvi,*

[2] *TPO & Asst. Professor, Department of Mechanical Engineering, R V Parankar College of Engineering & Technology, Arvi,*

[3,4,5,6,7,8] *Students, Department of Mechanical Engineering, R V Parankar College of Engineering & Technology, Arvi,*

***Abstract*—Domestic water pumps play an important role in residential water-supply systems, particularly where water must be transferred from underground storage tanks, wells, or other sources to overhead tanks and household distribution points. Despite their widespread use, these pumps may experience operational problems associated with unsuitable selection, poor installation, water contamination, mechanical deterioration, electrical faults, and inadequate maintenance. Such problems can result in reduced discharge, abnormal noise, vibration, leakage, overheating, and increased electricity consumption. This paper presents a critical narrative review of domestic water pumps, focusing on their operating principles, common failure mechanisms, energy-efficiency considerations, and maintenance practices. Evidence from published studies on household submersible pumps, centrifugal-pump failures, and water-pumping-system efficiency is examined to identify recurring problems and practical improvement measures. The review indicates that pump reliability depends on the interaction between pump components, water quality, operating conditions, installation arrangements, and maintenance practices. Appropriate pump selection, prevention of dry running, inspection of suction and delivery lines, suitable electrical protection, and timely maintenance may help improve service reliability. However, the available literature has limitations in its coverage of household-specific energy consumption, maintenance costs, and long-term performance under Indian residential conditions. The paper identifies these limitations and proposes research directions for developing more reliable, energy-efficient, and affordable domestic water-pumping systems.**

***Index Terms*—Domestic water pumps; centrifugal pumps; submersible pumps; operational problems; energy efficiency; preventive maintenance; household water supply.**

I. INTRODUCTION

Water is an essential requirement for residential buildings, and its reliable distribution depends on suitable storage, piping, and pumping arrangements. In many households, particularly in areas where water is supplied intermittently or where groundwater is used, pumps are required to transfer water from a source to an overhead storage tank or a household distribution system.

Domestic water pumps are available in several configurations, including surface-mounted centrifugal pumps, self-priming pumps, and submersible pumps. Their selection depends on the water source, required discharge, vertical lifting height, pipe-system resistance, and installation conditions.

Although domestic pumps are generally compact machines, their operation involves interactions among hydraulic, mechanical, and electrical components. An obstruction in the suction line, for example, may reduce water delivery, while bearing deterioration or impeller damage may produce abnormal noise and vibration. Electrical faults, inadequate cooling, and operation without sufficient water can also contribute to pump failure.

Kannaujia et al. [1] investigated a 1 hp household electrical submersible pump in Prayagraj, India, and discussed mechanical, electrical, and operational failure mechanisms. Their findings included problems associated with sand particles, hard water, component corrosion, leakage, and motor-related failures. This study provides a relevant example of household-pump failure, although its findings should not be assumed to represent every domestic installation.

McKee et al. [2] reviewed major centrifugal-pump failure modes, including hydraulic problems, bearing and seal failures, vibration, corrosion, and excessive power consumption. Shankar et al. [3] examined energy-efficiency improvement opportunities in centrifugal pumping systems, highlighting component selection, system sizing, and control strategies. Marwa et al. [4] investigated pump problems in rural water-supply projects and developed an approach for early fault identification.

These studies provide useful information on pump reliability and performance. However, evidence from industrial pumping systems and community water-supply infrastructure must be distinguished from evidence specifically concerning household pumps.

1.1 Research problem

Domestic water pumps are frequently used with limited routine inspection. When their performance deteriorates, household users may replace components or the entire pump without first identifying the underlying cause. This can increase maintenance expenditure and may leave the original problem unresolved.

There is therefore a need to consolidate existing evidence on common domestic-pump problems, their possible causes, the symptoms observed by users, and practical measures for improving energy efficiency and reliability.

1.2 Aim and objectives

The aim of this paper is to critically review the common operational problems, energy-efficiency considerations, and maintenance practices associated with domestic water pumps.

The specific objectives are:

- To describe the principal types and operating principles of domestic water pumps.
- To classify commonly reported hydraulic, mechanical, electrical, and operational problems.
- To examine factors that influence pump energy consumption and operating efficiency.
- To discuss preventive maintenance and practical fault-identification methods.
- To identify research gaps relevant to domestic water pumps, particularly in Indian residential applications.

1.3 Scope of the review

The review focuses on pumps used for household water transfer, storage-tank filling, and domestic water supply. Surface-mounted centrifugal pumps and submersible pumps receive particular attention.

The paper is based on published literature and technical interpretation. It does not present new experiments, field measurements, numerical simulations, or surveys conducted by the authors.

II. REVIEW METHODOLOGY

A narrative literature-review approach was adopted to examine published information relating to domestic water-pump performance, failure mechanisms, energy efficiency, and maintenance.

The principal sources considered were:

- A household submersible-pump failure investigation conducted in Prayagraj, India [1].
- A review of major centrifugal-pump failure modes in water-supply and sewerage applications [2].
- A review of energy-efficiency improvement methods for centrifugal pumping systems [3].
- A study of pump fault identification in rural water-supply projects [4].

The selected literature was examined under four themes: pump operating principles, operational and component failures, energy-efficiency considerations, and maintenance practices. Particular attention was given to findings that could reasonably inform domestic-pump operation.

The review is narrative rather than systematic. It does not claim to include every relevant publication, and no quantitative meta-analysis or formal statistical synthesis was performed. Furthermore, studies of industrial and community water-supply pumps were used only to explain potentially relevant failure mechanisms; their reported frequencies and

performance figures were not treated as representative of household pumps.

III. TYPES AND OPERATING PRINCIPLES OF DOMESTIC WATER PUMPS

3.1 Surface-mounted centrifugal pumps

Centrifugal pumps are widely used for water transfer because they provide continuous flow through the action of a rotating impeller. An electric motor supplies mechanical energy to the impeller, which transfers energy to the water. The pump casing and discharge passage guide the water towards the delivery pipe.

The resulting discharge and pressure depend on the pump characteristics and the resistance of the connected piping system. The required performance is influenced by vertical lifting height, pipe length, pipe diameter, bends, valves, and the condition of the pump itself.

A surface-mounted pump also depends on suitable suction conditions. Air leakage, inadequate priming, a blocked suction passage, or an insufficient water level may prevent normal operation.

3.2 Self-priming pumps

Self-priming pumps are designed to assist air removal from the suction arrangement under specified conditions. They may be useful in household installations where the pump is located above the water source.

However, self-priming capability does not mean that the pump can operate indefinitely without water. Initial filling requirements, maximum suction lift, and operating limitations must be followed according to the manufacturer's instructions.

3.3 Submersible pumps

Submersible pumps operate while immersed in the water being pumped. They are commonly used in borewells and wells and may also be installed in suitable underground water-storage arrangements.

A submersible pumping unit generally includes a motor and a pumping section. In multistage designs, impellers impart energy to the water while diffusers help convert velocity energy into pressure.

Kannaujia et al. [1] reported failures involving motor and pump components in a household submersible-pump investigation. The study highlights the importance of considering water quality and operating conditions alongside the condition of individual components.

3.4 Pump selection for household applications

Pump selection should be based on the requirements of the complete water-supply system rather than motor horsepower alone.

Required water discharge and household demand.

Total lifting height and resistance in the pipe system.

Water-source depth and availability.

Suction conditions and installation position.

Water quality and the presence of suspended particles.

Electrical supply and protection requirements.

Availability of maintenance services and replacement components.

An unsuitable pump may fail to provide the required water delivery or may operate under conditions that are less efficient than intended. Correct selection is therefore an important first step in improving household-pump performance.

IV. COMMON OPERATIONAL PROBLEMS IN DOMESTIC WATER PUMPS

Pump problems can be classified into hydraulic, mechanical, electrical, and operational categories. In practice, these categories may overlap. For example, a blocked suction line can lead to poor water delivery and abnormal operating conditions, while prolonged overloading may contribute to motor overheating.

4.1 Low or no water discharge

Low discharge is a common symptom of an underperforming pumping system. Possible causes include insufficient water at the source, blocked suction passages or filters, air entering the suction line, incorrect priming, leakage in the piping system, worn or damaged impeller components, and excessive resistance in the delivery line.

The first step should be to examine the water source, external piping, valves, and priming arrangement where applicable. Internal pump damage should not be assumed without checking other possible causes.

Marwa et al. [4] included no or low flow among the reported problems in rural water-supply pumping systems. Although those results do not establish the frequency of this fault in homes, they support the

importance of recognising reduced water delivery as a symptom requiring investigation.

4.2 Excessive noise and vibration

Noise and vibration can arise from loose mounting arrangements, bearing deterioration, impeller damage, misalignment, air entering the system, or unsuitable hydraulic operating conditions.

McKee et al. [2] identified vibration and mechanical and hydraulic faults among the major centrifugal-pump failure mechanisms. In a household installation, vibration may also be amplified by a poorly supported base or pipes that are not adequately secured.

Persistent abnormal noise should be investigated rather than treated as a normal characteristic of pump operation. Severe vibration, overheating, or a burning smell warrant switching off the pump and arranging professional inspection.

4.3 Leakage

Leakage may occur at pipe joints, seals, casing connections, or other parts of the installation. It can reduce the amount of water delivered to the intended destination and may expose electrical equipment to moisture.

The corrective action depends on the location and cause of the leak. External pipe connections may require resealing or replacement, whereas damaged internal seals or casing components may require qualified servicing.

Seal failure is among the pump problems discussed in the literature on water-supply systems [2,4]. However, the frequency of seal failure in domestic pumps requires further household-specific investigation.

4.4 Motor overheating and electrical failure

Electrical problems may involve damaged cables, loose connections, unsuitable supply conditions, motor winding faults, or protective devices that repeatedly trip.

Overheating can be associated with excessive loading, inadequate cooling, mechanical resistance, or operation under unsuitable conditions. The exact cause depends on the pump and motor design.

The household submersible-pump study by Kannaujia et al. [1] discusses cable, motor, and connection-related failures. It demonstrates why the electrical section should be considered alongside the hydraulic and mechanical sections during fault diagnosis.

Users should not open electrical enclosures or attempt internal motor repairs without appropriate training. A pump that repeatedly trips a protective device should be inspected by a qualified technician.

4.5 Dry running

Dry running occurs when a pump operates without an adequate supply of water. Depending on the pump design, it may cause overheating, damage to seals, or deterioration of internal components.

Possible contributing factors include a depleted source, blocked suction passages, loss of priming, or failure of an automatic water-level control.

Prevention measures include monitoring source-water availability, maintaining the suction arrangement, and using suitable low-water protection where appropriate. Such protection must be compatible with the pump and installed according to the manufacturer's recommendations.

4.6 Sand, sediment, scaling, and corrosion

Water quality can influence pump performance and component life. Suspended particles may contribute to abrasion, blockage, and deterioration of internal clearances. Depending on the water chemistry and materials used, corrosion and mineral deposits may also occur.

Kannaujia et al. [1] discussed the influence of sand particles and hard water in a household submersible-pump case study from Prayagraj. Their findings indicate that water quality should be considered when investigating repeated pump failures.

Suitable source protection, appropriate filtration, and periodic inspection may help reduce these risks. However, a filter must be selected and maintained correctly because a blocked filter can restrict water flow.

V. ENERGY EFFICIENCY OF DOMESTIC WATER PUMPS

Electricity consumption is an important consideration because domestic pumps may operate repeatedly to fill storage tanks or supply water. Their energy use depends on electrical input power, operating duration, hydraulic load, and the overall efficiency of the pumping system. Shankar et al. [3] reviewed energy-efficiency improvements in centrifugal pumping systems and discussed component selection, pipe-

system sizing, and control strategies. Although their review is not restricted to household pumps, these principles are relevant when considering residential pumping arrangements.

5.1 Pump and system matching

A pump should be selected to meet the required water flow and lifting height under the expected operating conditions. Selecting a pump based solely on motor rating may result in a mismatch between the pump's performance and the household system's requirements. The system includes the pump, motor, suction arrangement, delivery piping, valves, and storage tank. Losses or restrictions in any of these elements may affect the overall result.

5.2 Operating duration

The time for which a pump runs directly influences its electricity consumption. Unnecessary operation after a tank has reached its required water level can waste electricity and may increase wear.

Suitable tank-level controls can stop the pump when filling is complete, provided the controls are properly selected and maintained.

5.3 Mechanical condition

Worn impellers, bearing problems, leakage, and deteriorated internal components may affect pump performance. A pump that delivers less water than expected may consequently need to run for longer to meet the same household requirement.

Inspection and timely repair can help address such problems. However, the actual energy benefit of a repair depends on the original fault and the condition of the system.

5.4 Piping and hydraulic losses

Pipe diameter, pipe length, bends, valves, and restrictions influence the resistance against which a pump operates. Poorly arranged piping may increase the energy required to deliver a given quantity of water.

The energy-efficiency review by Shankar et al. [3] highlights the importance of appropriate system sizing and component selection. For domestic applications, these principles support selecting suitable pipework and avoiding unnecessary restrictions.

5.5 Practical energy-saving measures

Potential measures for household users include:

- Selecting a pump appropriate for the required flow and lifting height.
- Repairing leaks in pipes and connections.
- Keeping suction passages and filters clean.
- Preventing unnecessary running after the tank is full.
- Avoiding operation without adequate water.
- Investigating unusual noise, vibration, or reduced discharge.
- Maintaining the pump according to the manufacturer's recommendations.

These measures are practical recommendations rather than measured findings from the present review. No specific percentage of electricity savings can be claimed without measurements under defined operating conditions.

VI. PREVENTIVE MAINTENANCE PRACTICES

Preventive maintenance aims to identify deterioration before it results in major failure. For household pumps, it can combine simple user-level observations with periodic technical inspection.

6.1 Routine visual inspection

Householders can periodically observe whether water delivery is normal; visible joints or pipes are leaking; unusual noise or vibration is present; the pump starts and stops as expected; the source contains sufficient water; the storage-tank control operates correctly; and there are signs of overheating or damaged cables.

These observations can help identify warning signs but cannot replace professional diagnosis.

6.2 Periodic technical inspection

A qualified technician can inspect electrical connections, protective devices, mounting arrangements, bearings, seals, and internal components according to the pump design and service conditions.

The appropriate inspection interval should follow the manufacturer's guidance and account for operating frequency, water quality, and observed condition. A single maintenance schedule is unlikely to be suitable for every domestic installation.

6.3 Maintenance of suction and delivery lines

Suction lines, strainers, valves, and delivery pipes should be kept in suitable operating condition. Restrictions, leakage, and incorrect valve positions can affect water delivery.

Any cleaning or repair should be performed with the equipment safely isolated and in accordance with the pump manufacturer's instructions.

6.4 Electrical and operational safety

Water and electrical equipment create a potential safety hazard. Before inspection or maintenance, the pump's power supply should be isolated using appropriate procedures.

Users should avoid handling electrical equipment with wet hands, operating pumps with visibly damaged cables, or opening electrical enclosures without appropriate training.

A pump showing repeated tripping, severe vibration, or a burning smell should be switched off and assessed by a qualified professional.

6.5 Maintenance records

A basic maintenance record can include the date of inspection, observed symptoms, repairs carried out, components replaced, and changes in water delivery.

Such records may help identify recurring problems and support decisions about whether further repair or eventual replacement is appropriate.

VII. CRITICAL DISCUSSION

The reviewed literature indicates that domestic-pump reliability should be considered as a system-level issue. Mechanical components, electrical equipment, hydraulic conditions, water quality, installation arrangements, and maintenance practices interact to influence performance.

The household submersible-pump investigation by Kannaujia et al. [1] is particularly relevant because it examines a pump used for domestic purposes in India. It discusses mechanical, electrical, and operational failures and highlights water-quality concerns. Nevertheless, a case study of a particular pump and location cannot establish the relative frequency of failures across all household installations.

The review by McKee et al. [2] provides a broader explanation of centrifugal-pump fault mechanisms, while Shankar et al. [3] examine energy-efficiency improvement methods. These publications provide technical foundations for understanding failure and efficiency, but much of their scope extends beyond domestic applications. Similarly, Marwa et al. [4] report pump problems in rural water-supply projects. Their findings can inform the discussion of fault identification and maintenance, but community water-supply systems differ from individual household installations in operating patterns, equipment size, and maintenance arrangements.

An important limitation in the available evidence is the lack of a directly comparable dataset covering domestic pumps across different household types, water sources, regions, and operating schedules. The available studies do not support a reliable universal ranking of domestic-pump failure causes or a single estimate of household energy waste.

Therefore, the principal contribution of this review is to bring together relevant failure mechanisms, energy-efficiency principles, and maintenance recommendations while identifying the limits of applying broader pump research to household settings.

VIII. RESEARCH GAPS AND FUTURE SCOPE

8.1 Household-specific failure statistics

Studies involving a representative range of domestic pumps are needed to identify the most frequent failure types under different residential conditions. Such studies could record pump type, service age, water source, installation arrangement, maintenance history, and repair outcome.

8.2 Energy consumption under actual operating conditions

Field measurements could examine how pump rating, lifting height, delivery requirements, operating duration, and control arrangements affect household electricity consumption.

Comparisons should use clearly defined conditions and measurements rather than assuming that a particular pump type always consumes less electricity.

8.3 Relationship between water quality and component life

Further research could investigate the relationship between suspended particles, water hardness, corrosion, deposits, and the service life of impellers, seals, and other components.

8.4 Effectiveness of low-cost protection devices
The performance and affordability of tank-level controls, low-water protection, and suitable electrical protection could be evaluated in household installations.

8.5 Maintenance costs and repair decisions
Research comparing repair costs, replacement costs, operating performance, and service life could help households make better-informed decisions about pump maintenance and replacement.

8.6 Maintenance awareness among household users
Survey-based studies could investigate how users identify faults, arrange repairs, and follow manufacturer recommendations. The findings could support the development of accessible maintenance guidance.
These research directions could be addressed through field surveys, case studies, experimental testing, or monitoring of representative domestic installations. They are proposed areas for future work rather than results established by this review.

IX. CONCLUSION

Domestic water pumps are essential components of residential water-supply systems, and their performance depends on appropriate selection, correct installation, adequate water availability, and suitable maintenance. Common operational symptoms include low discharge, failure to start, leakage, abnormal noise, vibration, overheating, and repeated electrical tripping.
The reviewed literature shows that pump problems may arise from interacting mechanical, hydraulic, electrical, and operational factors. Water quality is also relevant, particularly where sand, suspended particles, or mineral deposits affect pump components. Energy efficiency should be considered alongside reliability. Appropriate pump selection, suitable piping, leak prevention, avoidance of unnecessary operation, and timely maintenance can support better household-pump performance. Nevertheless, the amount of energy saved by any individual measure depends on the specific installation and must be established through suitable measurements.
The review also identifies an evidence gap in household-specific research, particularly concerning failure frequencies, electricity consumption, maintenance costs, and long-term reliability under Indian residential conditions. Further field-based studies could help translate established pump-engineering principles into practical guidance for household users.
Overall, a combination of appropriate selection, safe operation, fault identification, and preventive maintenance provides a practical foundation for improving the reliability and efficiency of domestic water pumps.

Table 1. Common domestic-pump symptoms, possible causes, and practical responses

Observed symptom	Possible causes	Suggested response
Pump does not start	Supply interruption, damaged cable, control fault, motor fault	Check accessible controls; arrange electrical inspection
Low water delivery	Low source level, blockage, air leakage, worn components	Inspect source, pipes, valves, and priming
Water leakage	Damaged joints, seals, or connections	Locate leakage and repair or replace affected parts
Abnormal noise or vibration	Lose mounting, bearing wear, impeller damage, hydraulic disturbance	Stop if severe; arrange inspection
Excessive heating	Overloading, poor cooling, dry running, mechanical resistance	Switch off and identify the cause
Repeated protective-device tripping	Electrical fault, overload, or mechanical problem	Avoid repeated restarting; contact a qualified technician
Repeated wear or blockage	Sand, sediment, mineral deposits, unsuitable water conditions	Assess water quality and suitable protection

Note: The causes listed are diagnostic possibilities, not definitive diagnoses. Actual corrective actions depend on the pump design and installation.

REFERENCES

[1].V. Kannaujia, S. P. Bhore, and H. S. Goyal, "A case study on the failure analysis of 1 hp household electrical submersible pump in Prayagraj India," Engineering Failure Analysis, vol. 156, Art. no. 107742, 2024. doi: 10.1016/j.engfailanal.2023.107742.

[2].K. K. McKee, G. Forbes, M. I. Mazhar, R. Entwistle, and I. Howard, "A review of major centrifugal pump failure modes with application to the water supply and sewerage industries," in Proc. ICOMS Asset Management Conference, Gold Coast, Australia, 2011. Available: https://hdl.handle.net/20.500.11937/28560.

[3].V. K. A. Shankar, V. Kalaiselvan, U. Subramaniam, S. Paramasivam, and N. Hanigovszki, "A comprehensive review on energy efficiency enhancement initiatives in centrifugal pumping system," Applied Energy, vol. 181, pp. 495–513, 2016. doi: 10.1016/j.apenergy.2016.08.070.

[4].L. I. Marwa, S. Munishi, and T. B. Mwamila, "Know-what, know-when and know-how: A web and mobile-based android application for early detection of pump failures in rural water supply projects, Tanzania," Water Practice & Technology, vol. 17, no. 11, pp. 2447–2462, 2022. doi: 10.2166/wpt.2022.136.